



Sewer Pump Station Generator Replacement
PROJECT NUMBER: 24-26

ADDENDUM NO. 2

ISSUED THIS DATE: June 26, 2024

BID OPENING: 2:00 PM (PST) on Thursday, June 27, 2024

This addendum is for the 2024 Sewer Pump Station Generator Replacement project, Project No. 24-26, issued June 20, 2024. The document is posted to amend the acceptable dimensions of the generator package. Agency clarification is provided.

The addendum shall become fully a part of the above-named project drawing, specifications, and bid documents. Each bidder shall be responsible for reading this addendum to ascertain to what extent and in what manner it affects the work to be performed. All bidders must acknowledge their receipt of this addendum on the Bid Form.

This Addendum consists of a total of one (1) pages, consisting of the following:

1. ADDENDUM No. 02, dated June 26, 2024. Total of 1 page.

Modifications to the Contract Documents

1. **MODIFY** paragraph 7 of the Fuel System item description in Section 16.91.2 Diesel Engine Generator Set (**page 16-28 of the technical specification**) as follows:

7. The fuel tank shall be sized so that the combined fuel tank and generator package does not exceed the following dimensions:

- ~~a. 74" Long~~ → **76" Long**
- ~~b. 31" Wide~~ → **39" Wide**
- ~~c. 68" Tall~~ → **70" Tall**

Supplier must confirm that adequate clearance is maintained around the generator with sufficient room for the silencer, cooling air ducting and circuit breaker access.